

Conformity Attestation

No.: KIWA-20-DW-10004

of the certification body

regarding the suitability of products for drinking water hygiene – P1

Product: COPRAX - PP-R pipes and fittings (blue)-P1
Temperature 23°C and 60°C (cold and warm water)

Manufacturer: **Prandelli S.p.A.**

Via Rango 58
25065 Lumezzane (BS)
Italy

- based on typetesting (without external supervision; simplified procedure)
- according to system 1+ with external monitoring for the following production sites:

- 25065 Lumezzane, Italy

Reference / confirmation:

It is hereby confirmed that the above mentioned product / component

- based on the certification program "D6 KTW-UBA dated 2019-04-16-Rev03" of the certification body:
„Kiwa GmbH, Gutenbergstr. 29, 48268 Greven“,
- the product information provided, including the recipe evaluation, workorder no. 181000655,
- the evaluation reports mentioned on page 2.

fulfills the requirements of the assessment basis/guideline of the Federal Environment Agency (UBA):

„Conformity attestation of product hygiene suitability for drinking water“

Greven, 09.07.2020



i.V. D. Altemeier
- Deputy Head of Certification Body -



Valid from 09.07.2020

Valid until 17.03.2025

Number of pages 2

The publication of the certificate is permitted.

Replaces
First edition

CERTIFICATE

Kiwa GmbH
Gutenbergstr. 29
48268 Greven
Deutschland

Tel: +49 (0)2571 9872-0
Fax: +49 (0)2571 9872-99

info@kiwa.de
www.kiwa.de

Director:
Prof. Dr. Roland Hüttl

QM F Z A 101 h-1/R.1

- Page 1 / 2 -



This conformity attestation also applies to the following products / components:

Product / component: **COPRAX - PP-R-Pipe, blue, and fittings**

- Pipe: PN20-SDR6: diameters 20 – 110mm and fittings
- Pipe: PN16-SDR7: diameters 32 – 125mm and fittings
- Pipe: PN10-SDR11: diameters 20 – 125mm and fittings
- Fittings: PN20-SDR6 diameters 20 – 125mm

The following mentioned assessment reports/test reports, (deposited at Kiwa)

Testreport: **KIWA 031900027-0016 of 17.03.2020**
migration requirements according KTW-BWGL

Testreport: **KIWA 031900027-0016-1 of 15.04.2020**
enhancement of microbial growth according KTW-BWGL

are part of the conformity attestation.

The confirmation of conformity is valid from the date of issue and remains valid until 18.04.2025 as long as the conditions listed under "Notes" are fulfilled.

Notes:

The conformity attestation was issued under the condition that the starting materials used to manufacture the product or their composition and/or components, including their manufacturer and supply chain, were fully disclosed and no other substances are contained in the product.

The validity of this document expires in case of changes in the composition of the product or in the processing conditions not agreed with the certification body and in case of non-compliance with the conformity requirements as well as in case of termination of the 1+ system monitoring programme of the certification body and manufacturer.

The results of our audits and the assessments apply to the test items examined and the statutory regulations applicable at the time of the audit. This document may only be published or reproduced in complete and unchanged form without our express written consent.

CERTIFICATE

Kiwa GmbH

Gutenbergstr. 29
48268 Greven
Deutschland

Tel: +49 (0)2571 9872-0
Fax: +49 (0)2571 9872-99

info@kiwa.de
www.kiwa.de

Director:
Prof. Dr. Roland Hüttl

QMF ZA 101 h-1/R.1